

Government of India
Ministry of Commerce & Industry
Department of Commerce
Directorate General of Supplies & Disposals

Telephone : Office of the Director Of Quality Assurance
Fax : Nizam Palace, 2 nd Ms Bldg, 234/4, Acharya
Telegram : J.C. Bose Rd
E-Mail : Kolkata-700020
Website : <http://dgsnd.gov.in>

REGISTRATION CERTIFICATE

To Dated : 04-SEP-2012

M/s DS SYSTEMS PVT. LTD. (Supplier Code : 06362)
4, Sundarpur, R.G. Baruah Road,
Guwahati
781005

Ref:- Your Application No. DSSPL/2012-13/DGS&D/001 Dated : 27-AUG-2012

Dear Sir,

Your request for registration with Directorate General of Supplies & Disposals (DGS&D) has been accepted and your name has been included in the list of registered suppliers as per details given hereunder and in the attached Schedule.

Registration No.: DGS&D/Regn/KOL/S-4620/12/06362 Valid upto : As indicated Workwise

Category of registration : Manufacturer Whether SSI Unit : Yes

Name of the firm : DS SYSTEMS PVT. LTD.

Office Address, E-Mail ID, Telephone nos.

a) Registered Office	b) Corporate/Head Office
4, Sundarpur, R.G. Baruah Road,	Odalbakra
Guwahati	Guwahati
9678008031	9678008031
info@dssystems.in	info@dssystems.in

c) Correspondence Address

Date of incorporation : 03-JAN-2008

Constitution of the firm : Private Limited

Name of Managing Director/Partner/Proprietor

- 1 Debajyoti Nath
- 2 Utpal Barbara
- 3 Samor Borbara
- 4 Mridusmita Barman

Permanent Account No. (PAN): AACCD8183C

Annual Turnover	:Year	Rs. (In Lacs)	
	2010-2011	1819.49	With Profit
	2009-2010	1125.62	With Profit
	2008-2009	805.8	With Profit

Monetry Limit (Rs.) : Without any limit

The registration is subject to Conditions of Registration as enclosed and as prescribed by DGS&D from time to time. Stores will be offered for customer's testing and inspection at the premises specified in the Schedule. This Certificate is to be produced only in full and complete with amendments if any. Please quote your registration no. in all future correndondence with DGS&D.

Yours faithfully,



[Signature]
Deputy Director (Registration)
for Director General of Supplies & Disposals

Schedule to Registration No. KOL/S-4620/12/06362

Dated : 04-SEP-2012

S.No Works Name & Address

Validity : 03-SEP-2013

1 DS SYSTEMS PVT. LTD.

Odalbakra
Guwahati-781034
9678008032
03612470158

Sales tax registration No. 18220096636

Date :

CST registration No. 18899927155

Date :

Excise Duty Registration No.

Authority

S.No	Description of Stores	Governing Specification/ Eligibility Criteria	Model/ Brand	Prod.Capacity/ Dt.of Approval
1	Line Interactive UPS with AVR for single phase AC 160V to 280V input.	Line Interactive UPS with AVR and PWM technology for computers suitable for single phase AC input voltage range 160V to 280V, 50 +/-3 Hz and single phase AC output voltage 230V +/-9%, 50+/-0.5 Hz in AC mode. It shall be housed in rugged enclosure made of M.S. sheet of 1 mm (minimum) thick aesthetically finished, duly pretreated and powder coated or ABS body.	"ORION"	640 Nos. of assorted rating/Month/Shift. 04-SEP-2012
2	On-Line UPS with isolation transformer suitable for Three Phase AC Input and Three Phase AC Output, Floor Mounted Type	On-line UPS with isolation transformer & with PWM technology, floor mounted type suitable for three phase AC input voltage 300V to 450V, 50+/-1.5 Hz and three phase AC output voltage 400V +/-1%V, 50 +/-0.5Hz. It shall be housed in rugged enclosure made of M.S. sheet 1.2 mm (minimum) thick, aesthetically finished, duly pretreated and powder coated. UPS input factor is 0.95 & Out put Power factor is 0.8, Isolation transformer or 1:1ratio is provided & as per DGS&D Tender Enquiry No.On-LineUPS/IT-4/RC-D3070000/1113/84.	:ORION- ASTRA"	60 Nos. of assorted rating/Month/Shift. 04-SEP-2012



- | | | | | |
|---|---|--|---------------|--|
| 3 | On-Line UPS with isolation transformer suitable for Three Phase AC Input and Single Phase AC Output, Floor Mounted Type | On-line UPS with isolation transformer & with PWM technology, floor mounted type suitable for three-phase AC input voltage 300V to 450V, 50 +/-1.5 Hz and single phase AC output voltage 230 +/-1%V, 50+/-0.5Hz. It shall be housed in rugged enclosure made of M.S sheet 1.2 mm (minimum) thick, aesthetically finished, duly pretreated and powder coated.
UPS In put power factor 0.95 & out power factor 0.8, Isolation transformer of 1:1ratio is provided & as per DGS&D Tender Enquiry No. ON-LINEUPS/IT-4/RC-D3070000/1113/84. | "ORION-ASTRA" | 60 Nos. of assorted rating/Month/Shift.

04-SEP-2012 |
| 4 | On-Line UPS with isolation transformer suitable for single phase AC input & single phase AC output, Floor Mounted Type | On-line UPS with isolation transformer & with PWM Technology, Floor mounted type suitable for single phase AC input voltage 160V to 260V, 50+/-1.5Hz and single phase AC output voltage 230+/-1%V, 50+/-0.5Hz. It shall be housed in a rugged enclosure made of M.S Sheet 1.2 mm(minimum) thick ,aesthetically finished, duly pretreated and powder coated .
UPS In put power factor 0.95 & Out put power factor 0.8, Isolation transformer of 1:1 ratio is provided & as per DGS&D Tender Enquiry No. ON-LINEUPS/IT-4/RC-D3070000/1113/84. | :ORION-ASTRA" | 100 Nos. of assorted rating /Month/Shift.

04-SEP-2012 |

No. of items registered (work wise) : 4

* ANNEXURE Attached

Copy to:



[Handwritten signature]

1. Director of Quality Assurance, [controlling officer]
2. Director of Supplies [concerned purchase Dte(s), DGS&D, New Delhi.
3. Director (Registration) / Director (MIS) DG (S&D), New Delhi
4. Guard File

Please Note:

1. This supersedes the earlier Registration Certificate if any
2. This registration is an indication of the capability of the registered firm. For further assurance on quality, the Purchasers are advised to avail the inspection services offered by the Quality Assurance Wing of DGS&D.
3. Authenticity of this certificate can be verified by the government indentors and purchasers
4. Onus for verification of the firm's ITCC before award of Contract will rest with the purchaser.



[Handwritten signature]

ANNEXURE

DS SYSTEMS PVT. LTD.

Odalbakra

Guwahati-781034

9678008032

03612470158

*Line Interactive UPS with AVR for single phase AC 160V to 280V input.***Limiting Size / Grade / Type**

1 Rated KVA Minimum VAH

0.5 400
0.65 400
0.8 400
1.0 800
1.5 800
2.0 1600

*On-Line UPS with isolation transformer suitable for Three Phase AC Input and Three Phase AC Output, Floor Mounted Type***Limiting Size / Grade / Type**

1 Rating of UPS Indicative Back-Up time

10 KVA 120 minutes
15 KVA 120 minutes
20 KVA 120 minutes
30 KVA 120 minutes.

*On-Line UPS with isolation transformer suitable for Three Phase AC Input and Single Phase AC Output, Floor Mounted Type***Limiting Size / Grade / Type**

1 Rating of UPS Indicative Back-Up time

10 KVA 120 minutes
15 KVA 120 minutes
20 KVA 120 minutes
30 KVA 120 minutes.

*On-Line UPS with isolation transformer suitable for single phase AC input & single phase AC output, Floor Mounted Type***Limiting Size / Grade / Type**

1 Rating of UPS Indicative Back-up time

1.0KVA 120 Minutes
2.0 KVA 120 Minutes
3.0 KVA 120 Minutes
5.0 KVA 120 Minutes
6.0 KVA 120 Minutes
7.5 KVA 120 Minutes
10 KVA 120 Minutes.



[Handwritten signature]

Conditions of Registration

1. Registered firms are to abide by the General Conditions of contracts contained in DGS&D-68 (revised and DGS&D-1001 from time to time.
2. It is obligatory on the part of the registered firms to furnish performance statement in format prescribed in the Application Form every year indicating all orders placed on them.
3. Registered firms are required to keep Registering Authority informed about the changes in any of the particulars furnished by them in their application or in their product specification or discontinuation of production of any item for which they stand registered. This intimation is to be given within a period of 15 days from the date of such change or discontinuation.
4. Registered firms are required to furnish all the documents having specific validity periods like BIS license, lease agreement, agreement with the principal/manufactures to registering authority as and when they become due. Separate application shall be made for such unit, where firm has more than one manufacturing units. Requests for change in the of a firm and/or their office address should be addressed to the Registration office/centre who granted the documentary evidence. In the event of any change in the constitution of the firm or in the location of their manufacturing works, the registration with DGS&D shall lapse. The firm should surrender the original registration certificate in such cases and apply for registration afresh.
5. In cases where stores are manufactured by a firm other than the supplier, the manufacturer has given a back up warranty for the stores supplied. It will be responsibility of the supplier/manufacturer (both in case they are different) to ensure availability of spares for at least period of 7 years after the date of supply.
6. All registered firms are expected to maintain absolute integrity, follow a decent standard of business ethics and do nothing unbecoming of a registered supplier.
7. Fresh application with prescribed fee shall be required to be made after expiry of previous registration or for seeking additional registration/change of specification.
8. DGS&D registration is one of the requirements for the suppliers to participate in DGS&D tenders. The tenders may stipulate other requirements/eligibility criteria which are also required to be compelled with.
9. The registration on the approved list does not guarantee award of any contract. In their quotation against tenders, registered firms are to quote their registration number, along with clear statement that the tenderer is registered for that particular store with DGS&D.
10. In all future correspondence with the Registration Branch/Registering Authority of DGS&D, approved vendors are always required to quote the Registration No. given at the top of the registration letter.
11. Whenever registered firms are required to produce copy of their registered certificate copy of the original certificate complete with all the amendments including additions/deletions is made their after shall be produced.
12. The Government has right to add/delete any of the items and to amend any of the terms and conditions included in the registration granted to the firms with effect from any date specified in the communication
13. Failure to abide by the conditions of registration as above on any of the other grounds as listed under Para 5.17.2 of DGS&D Manual being applicable, name of a registered firm liable to be removed from the list of approved suppliers of DGS&D



[Handwritten signature]